

## NFPA 101 Revisions Regarding Door Operations and Door Hardware

### NFPA 101-2012 → NFPA 101-2015 → NFPA 101-2018 → NFPA 101-2021 → NFPA 101-2024

Revised June 2023

Note: the sequence of sections is based on the 2021 edition of NFPA 101, which was rearranged from the 2018 edition, starting with 7.2.1.5.2.

NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>i</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>ii</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
<b>7.1.9 Impediments to Egress.</b> (no device shall impede egress)		<b>7.1.9 Impediments to Egress.</b> (no device shall impede egress)	Revised to include monitored or recorded egress.	<b>7.1.9 Impediments to Egress.</b> (no device shall impede egress)		<b>7.1.9 Impediments to Egress.</b> (no device shall impede egress)	
<b>7.1.10 Means of Egress Reliability</b>		<b>7.1.10 Means of Egress Reliability</b>		<b>7.1.10 Means of Egress Reliability</b>		<b>7.1.10 Means of Egress Reliability</b>	
<b>7.1.10.1* Maintenance</b> (MOE shall be maintained for full instant use)		<b>7.1.10.1* Maintenance</b> (MOE shall be maintained for full instant use)		<b>7.1.10.1* Maintenance</b> (MOE shall be maintained for full instant use)		<b>7.1.10.1* Maintenance</b> (MOE shall be maintained for full instant use)	
<b>7.1.10.2 Furnishings and Decorations in Means of Egress.</b>		<b>7.1.10.2 Furnishings and Decorations in Means of Egress.</b>		<b>7.1.10.2 Furnishings and Decorations in Means of Egress.</b>		<b>7.1.10.2 Furnishings and Decorations in Means of Egress.</b>	
<b>7.1.10.2.1</b> (no furnishing shall . . . obstruct exits)		<b>7.1.10.2.1</b> (no furnishing shall . . . obstruct exits)		<b>7.1.10.2.1</b> (no furnishing shall . . . obstruct exits)		<b>7.1.10.2.1</b> (no furnishing shall . . . obstruct exits)	
<b>7.1.10.2.2</b> (no obstructions by railings)		<b>7.1.10.2.2</b> (no obstructions by railings)		<b>7.1.10.2.2</b> (no obstructions by railings)		<b>7.1.10.2.2</b> (no obstructions by railings)	

NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>1</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>11</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
7.1.10.2.3 (mirrors)		7.1.10.2.3 (mirrors)		7.1.10.2.3 (mirrors)		7.1.10.2.3 (mirrors)	
<b>7.2 Means of Egress Components.</b>		<b>7.2 Means of Egress Components.</b>		<b>7.2 Means of Egress Components.</b>		<b>7.2 Means of Egress Components.</b>	
<b>7.2.1 Door Openings</b>		<b>7.2.1 Door Openings</b>		<b>7.2.1 Door Openings</b>		<b>7.2.1 Door Openings</b>	
<b>7.2.1.1 General</b>		<b>7.2.1.1 General</b>		<b>7.2.1.1 General</b>		<b>7.2.1.1 General</b>	
<b>7.2.1.1.1</b> (door assembly in MOE shall comply with 7.1 and 7.2.1)		<b>7.2.1.1.1</b> (door assembly in MOE shall comply with 7.1 and 7.2.1)		<b>7.2.1.1.1</b> (door assembly in MOE shall comply with 7.1 and 7.2.1)		<b>7.2.1.1.1</b> (door assembly in MOE shall comply with 7.1 and 7.2.1)	
<b>7.2.1.1.2</b> (every door opening and principal entrance required to serve as MOE shall be obvious and direct)		<b>7.2.1.1.2</b> (every door opening and principal entrance required to serve as MOE shall be obvious and direct)		<b>7.2.1.1.2</b> (every door opening and principal entrance required to serve as MOE shall be obvious and direct)		<b>7.2.1.1.2</b> (every door opening and principal entrance required to serve as MOE shall be obvious and direct)	
<b>7.2.1.1.3 Occupied Building</b>		<b>7.2.1.1.3 Occupied Building</b>		<b>7.2.1.1.3 Occupied Building</b>		<b>7.2.1.1.3 Occupied Building</b>	
<b>7.2.1.1.3.1</b> (building considered occupied when)		<b>7.2.1.1.3.1</b> (building considered occupied when)		<b>7.2.1.1.3.1</b> (building considered occupied when)		<b>7.2.1.1.3.1</b> (building considered occupied when)	

NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>1</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>11</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
7.2.1.1.3.2 (not considered occupied when)		7.2.1.1.3.2 (not considered occupied when)		7.2.1.1.3.2 (not considered occupied when)		7.2.1.1.3.2 (not considered occupied when)	
7.2.1.2 Door Leaf Width.		7.2.1.2 Door Leaf Width.		7.2.1.2 Door Leaf Width.		7.2.1.2 Door Leaf Width.	
7.2.1.2.1* Measurement of Clear Width.		7.2.1.2.1* Measurement of Clear Width.		7.2.1.2.1* Measurement of Clear Width.		7.2.1.2.1* Measurement of Clear Width.	
7.2.1.2.1.1 Swinging Door Assemblies. (how to measure clear width)		7.2.1.2.1.1 Swinging Door Assemblies. (how to measure clear width)		7.2.1.2.1.1 Swinging Door Assemblies. (how to measure clear width)		7.2.1.2.1.1 Swinging Door Assemblies. (how to measure clear width)	
7.2.1.2.1.2 Other than Swinging Door Assemblies. (how to measure clear width)		7.2.1.2.1.2 Other than Swinging Door Assemblies. (how to measure clear width)		7.2.1.2.1.2 Other than Swinging Door Assemblies. (how to measure clear width)		7.2.1.2.1.2 Other than Swinging Door Assemblies. (how to measure clear width)	
7.2.1.2.2* Measurement of Egress Capacity Width.		7.2.1.2.2* Measurement of Egress Capacity Width.		7.2.1.2.2* Measurement of Egress Capacity Width.		7.2.1.2.2* Measurement of Egress Capacity Width.	
7.2.1.2.2.1 Swinging Door Assemblies. (how to measure egress capacity width)		7.2.1.2.2.1 Swinging Door Assemblies. (how to measure egress capacity width)		7.2.1.2.2.1 Swinging Door Assemblies. (how to measure egress capacity width)		7.2.1.2.2.1 Swinging Door Assemblies. (how to measure egress capacity width)	
7.2.1.2.2.2 Other than Swinging Door Assemblies. (how to measure egress capacity width)		7.2.1.2.2.2 Other than Swinging Door Assemblies. (how to measure egress capacity width)		7.2.1.2.2.2 Other than Swinging Door Assemblies. (how to measure egress capacity width)		7.2.1.2.2.2 Other than Swinging Door Assemblies. (how to measure egress capacity width)	

NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>1</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>11</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
<b>7.2.1.2.3 Minimum Door Leaf Width.</b>		<b>7.2.1.2.3 Minimum Door Leaf Width.</b>		<b>7.2.1.2.3 Minimum Door Leaf Width.</b>		<b>7.2.1.2.3 Minimum Door Leaf Width.</b>	
<b>7.2.1.2.3.1</b> (when to use clear width vs door leaf width)		<b>7.2.1.2.3.1</b> (when to use clear width vs door leaf width)		<b>7.2.1.2.3.1</b> (when to use clear width vs door leaf width)		<b>7.2.1.2.3.1</b> (when to use clear width vs door leaf width)	
<b>7.2.1.2.3.2</b> (doors in MOE min. 32” clear width, and 9 exceptions)		<b>7.2.1.2.3.2</b> (doors in MOE min. 32” clear width, and 9 exceptions)		<b>7.2.1.2.3.2</b> (doors in MOE min. 32” clear width, and 9 exceptions)		<b>7.2.1.2.3.2</b> (doors in MOE min. 32” clear width, and 9 exceptions)	Editorial clarifications of item 7 re: two-leaf power-operated doors.
<b>7.2.1.3 Floor Level.</b>		<b>7.2.1.3 Floor Level.</b>		<b>7.2.1.3 Floor Level.</b>		<b>7.2.1.3 Floor Level.</b>	
<b>7.2.1.3.1</b> (differences in elevation of floor on both sides of door)		<b>7.2.1.3.1</b> (differences in elevation of floor on both sides of door)		<b>7.2.1.3.1</b> (differences in elevation of floor on both sides of door)		<b>7.2.1.3.1</b> (differences in elevation of floor on both sides of door)	
<b>7.2.1.3.2</b> (distance from door 7.2.1.3.1 required)		<b>7.2.1.3.2</b> (distance from door 7.2.1.3.1 required)	For floor level req’t, added min. 36” from door.	<b>7.2.1.3.2</b> (distance from door 7.2.1.3.1 required)		<b>7.2.1.3.2</b> (distance from door 7.2.1.3.1 required)	
<b>7.2.1.3.3</b> (max threshold height)		<b>7.2.1.3.3</b> (max threshold height)		<b>7.2.1.3.3</b> (max threshold height)		<b>7.2.1.3.3</b> (max threshold height)	
<b>7.2.1.3.4</b> (bevel threshold / changes in floor height)		<b>7.2.1.3.4</b> (bevel threshold / changes in floor height)		<b>7.2.1.3.4</b> (bevel threshold / changes in floor height)		<b>7.2.1.3.4</b> (bevel threshold / changes in floor height)	
<b>7.2.1.3.5</b> (floor level exterior balcony or exit access)		<b>7.2.1.3.5</b> (floor level exterior balcony or exit access)		<b>7.2.1.3.5</b> (floor level exterior balcony or exit access)		<b>7.2.1.3.5</b> (floor level exterior balcony or exit access)	

DISCLAIMER: BHMA provides this information as a service. Refer to the jurisdiction’s building codes and the project requirements. If questions, consult the Authority Having Jurisdiction (AHJ).

NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>1</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>11</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
7.2.1.3.6 (door swing at top of stair)		7.2.1.3.6 (door swing at top of stair)		7.2.1.3.6 (door swing at top of stair)		7.2.1.3.6 (door swing at top of stair)	
7.2.1.3.7 (floor level to spaces not normally occupied)	New section addressing differences in floor level at spaces not normally occupied.	7.2.1.3.7 (floor level to spaces not normally occupied)		7.2.1.3.7 (floor level to spaces not normally occupied)		7.2.1.3.7 (floor level to spaces not normally occupied)	
7.2.1.4 Swing and Force to Open.		7.2.1.4 Swing and Force to Open.		7.2.1.4 Swing and Force to Open.		7.2.1.4 Swing and Force to Open.	
7.2.1.4.1* <b>Swinging-Type Door Assembly Requirement.</b> (req's doors in MOE to be swinging door, with 7 exceptions)	Req'd sign for security grills revised to "This door to remain open when the space is occupied."	7.2.1.4.1* <b>Swinging-Type Door Assembly Requirement.</b> (req's doors in MOE to be swinging door, with 7 exceptions)		7.2.1.4.1* <b>Swinging-Type Door Assembly Requirement.</b> (req's doors in MOE to be swinging door, with 7 exceptions)		7.2.1.4.1* <b>Swinging-Type Door Assembly Requirement.</b> (req's doors in MOE to be swinging door, with 7 exceptions)	
7.2.1.4.2 <b>Door Leaf Swing Direction.</b> (req'ts for when door is to swing in direction of egress travel)		7.2.1.4.2 <b>Door Leaf Swing Direction.</b> (req'ts for when door is to swing in direction of egress travel)		7.2.1.4.2 <b>Door Leaf Swing Direction.</b> (req'ts for when door is to swing in direction of egress travel)		7.2.1.4.2 <b>Door Leaf Swing Direction.</b> (req'ts for when door is to swing in direction of egress travel)	
7.2.1.4.3 <b>Door Leaf Encroachment.</b>	Section and subsections editorially revised for clarity.	7.2.1.4.3 <b>Door Leaf Encroachment.</b>		7.2.1.4.3 <b>Door Leaf Encroachment.</b>		7.2.1.4.3 <b>Door Leaf Encroachment.</b>	
7.2.1.4.3.1* (door swing, door leaf encroachment)		7.2.1.4.3.1* (door swing, door leaf encroachment)		7.2.1.4.3.1* (door swing, door leaf encroachment)		7.2.1.4.3.1* (door swing, door leaf encroachment)	
7.2.1.4.3.2 (max projection into required width)		7.2.1.4.3.2 (max projection into required width)		7.2.1.4.3.2 (max projection into required width)		7.2.1.4.3.2 (max projection into required width)	

NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>1</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>11</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
7.2.1.4.3.3 (surface mounted latch release hardware)		7.2.1.4.3.3 (surface mounted latch release hardware)		7.2.1.4.3.3 (surface mounted latch release hardware)		7.2.1.4.3.3 (surface mounted latch release hardware)	
7.2.1.4.4 Screen Door Assemblies and Storm Door Assemblies (req's for these items)		7.2.1.4.4 Screen Door Assemblies and Storm Door Assemblies (req's for these items)		7.2.1.4.4 Screen Door Assemblies and Storm Door Assemblies (req's for these items)		7.2.1.4.4 Screen Door Assemblies and Storm Door Assemblies (req's for these items)	
7.2.1.4.5 Door Leaf Operating Forces.		7.2.1.4.5 Door Leaf Operating Forces.		7.2.1.4.5 Door Unlatching and Leaf Operating Forces.	Revised title of section to separate forces to operate hardware from forces to open door.	7.2.1.4.5 Door Unlatching and Leaf Operating Forces.	
7.2.1.4.5.1 (forces required to open a door leaf shall not exceed)		7.2.1.4.5.1 (forces required to open a door leaf shall not exceed)		7.2.1.4.5.1 (forces required to unlock and unlatch not to exceed 15 lbf push, pull, or slide, or 28 in-lbf. by rotation)	New section with explicit max. forces to operate hardware.	7.2.1.4.5.1 (forces required to unlock and unlatch not to exceed 15 lbf push, pull, or slide, or 28 in-lbf. by rotation)	
7.2.1.4.5.2 (forces applied location)		7.2.1.4.5.2 (forces applied location)		7.2.1.4.5.2 (forces required to open a door leaf shall not exceed)		7.2.1.4.5.2 (forces required to open a door leaf shall not exceed)	
				7.2.1.4.5.3 (forces applied location)		7.2.1.4.5.3 (forces applied location)	
7.2.1.5 Locks, Latches, and Alarm Devices.		7.2.1.5 Locks, Latches, and Alarm Devices.		7.2.1.5 Locks and Latches.	Revised title of section.	7.2.1.5 Locks and Latches.	
7.2.1.5.1 (doors readily openable when occupied)		7.2.1.5.1 (doors readily openable when occupied)		7.2.1.5.1 (doors readily openable when occupied)		7.2.1.5.1 (doors readily openable when occupied)	

NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>1</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>11</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
<b>7.2.1.5.3</b> (locks – no key, tool, special knowledge or effort)		<b>7.2.1.5.3</b> (locks – no key, tool, special knowledge or effort)		<b>7.2.1.5.2</b> (locks and latches – no key, tool, special knowledge or effort)	Revised to include latches in req's.	<b>7.2.1.5.2</b> (locks and latches – no key, tool, special knowledge or effort)	
<b>7.2.1.5.10*</b> (latch releasing device obvious method of operation)		<b>7.2.1.5.10*</b> (latch releasing device obvious method of operation)		<b>7.2.1.5.3* Latch-Release Devices.</b> (latch releasing device obvious method of operation)		<b>7.2.1.5.3* Latch-Release Devices.</b> (latch releasing device obvious method of operation)	Clarification the req's address the egress side of the door.
<b>7.2.1.5.10.1</b> (Location AFF of latch releasing device)		<b>7.2.1.5.10.1</b> (Location AFF of latch releasing device)		<b>7.2.1.5.3.1</b> (Location AFF of latch releasing device)		<b>7.2.1.5.3.1</b> (Location AFF of latch releasing device)	
<b>7.2.1.5.10.2</b> (not more than one releasing operation unless specified in . . .)		<b>7.2.1.5.10.2</b> (not more than one releasing operation unless specified in . . .)	Added 7.2.1.5.10.6 and 7.2.1.5.10.7 where more than one releasing operation is permitted.	<b>7.2.1.5.3.2</b> (not more than one releasing motion unless specified in . . .)	Revised to require releasing of all latching and all locking devices with not more than one motion in a single linear or rotational direction.	<b>7.2.1.5.3.2</b> (not more than one releasing motion unless specified in . . .)	
				<b>7.2.1.5.3.3*</b> (for new installations, releasing mechanism operable with one hand . . .)	New section moved Annex text to mandatory text re: new installations req'd to be operable with one hand, and not require tight grasping, tight pinching, or twisting of the wrist.	<b>7.2.1.5.3.3*</b> (for new installations, releasing mechanism operable with one hand . . .)	
<b>7.2.1.5.10.3*</b> (where one additional releasing operation permitted)		<b>7.2.1.5.10.3*</b> (where one additional releasing operation permitted)		<b>7.2.1.5.3.4*</b> (where one additional releasing operation permitted)		<b>7.2.1.5.3.4*</b> (where one additional releasing operation permitted)	Adds req't for non-simultaneous releasing operations.
<b>7.2.1.5.10.4</b> (existing security devices per 7.2.1.5.10.3 permitted up to two additional releasing operations)		<b>7.2.1.5.10.4</b> (existing security devices per 7.2.1.5.10.3 permitted up to two additional releasing operations)		<b>7.2.1.5.3.5</b> (existing security devices per 7.2.1.5.3.4 permitted up to two additional releasing operations)		<b>7.2.1.5.3.5</b> (existing security devices per 7.2.1.5.3.4 permitted up to two additional releasing operations)	
<b>7.2.1.5.10.5</b> (existing security devices per 7.2.1.5.10.3 location)		<b>7.2.1.5.10.5</b> (existing security devices per 7.2.1.5.10.3 location)		<b>7.2.1.5.3.6</b> (existing security devices per 7.2.1.5.3.4 location)		<b>7.2.1.5.3.6</b> (existing security devices per 7.2.1.5.3.4 location)	

NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>1</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>11</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
7.2.1.5.10.6 (permits two releasing motions where occupant load <= 3)		7.2.1.5.10.6 (permits two releasing motions where occupant load <= 3)		7.2.1.5.3.7 (permits two releasing motions where occupant load <= 3)		7.2.1.5.3.7 (permits two releasing motions where occupant load <= 3)	
		7.2.1.5.10.7 (two releasing operations permitted where permitted by chapters 11-43 (classroom doors))	New section recognizing up to two releasing operations permitted in existing educational occupancies and existing day care occupancies.	7.2.1.5.3.8 (two releasing operations permitted in existing educational occupancies and existing day care occupancies)	Revised text permitting up to two releasing motions only in existing educational occupancies and existing day care occupancies.	7.2.1.5.3.8 (two releasing operations permitted in existing educational occupancies and existing day care occupancies)	
7.2.1.5.4 (not applicable where provided in chapters 18-23)		7.2.1.5.4 (not applicable where provided in chapters 18-23)		7.2.1.5.4 (not applicable where provided in chapters 18-23)		7.2.1.5.4 (not applicable where provided in chapters 18-23)	
7.2.1.5.2* (after exposure to a fire req's of 7.2.1.5.1 don't apply)		7.2.1.5.2* (after exposure to a fire req's of 7.2.1.5.1 don't apply)		7.2.1.5.5* (after exposure to a fire req's of 7.2.1.5.1 don't apply)		7.2.1.5.5* (after exposure to a fire req's of 7.2.1.5.1 don't apply)	
7.2.1.5.5 Key-Operated Locks.		7.2.1.5.5 Key-Operated Locks.		7.2.1.5.6 Key-Operated Locks.		7.2.1.5.6 Key-Operated Locks.	
7.2.1.5.7 (key operation permitted per chapters 11-43)		7.2.1.5.7 (key operation permitted per chapters 11-43)		7.2.1.5.6.1 (key operation permitted per chapters 11-43)		7.2.1.5.6.1 (key operation permitted per chapters 11-43)	
7.2.1.5.5.1 (key operated locks permitted on exterior doors. . .)		7.2.1.5.5.1 (key operated locks permitted on exterior doors. . .)		7.2.1.5.6.2 (key operated locks permitted on exterior doors and interior doors to individual tenant spaces. . .)	Revised to permit key operated locks on interior doors to individual or single tenant spaces, in addition to exterior doors to a building.	7.2.1.5.6.2 (key operated locks permitted on exterior doors and interior doors to individual tenant spaces. . .)	
7.2.1.5.5.2 (AHJ may revoke)		7.2.1.5.5.2 (AHJ may revoke)		7.2.1.5.6.3 (AHJ may revoke)		7.2.1.5.6.3 (AHJ may revoke)	



NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>1</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>11</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
7.2.1.5.8* (requirements for door assemblies in stair enclosures > 4 stories)		7.2.1.5.8* (requirements for door assemblies in stair enclosures > 4 stories)		7.2.1.5.7* Stair Enclosure Re-entry (requirements for door assemblies in stair enclosures > 4 stories)	Added name to section. Added req't for auto release door hardware to be listed to UL 294.	7.2.1.5.7* Stair Enclosure Re-entry (requirements for door assemblies in stair enclosures > 4 stories)	Added option for req'd listing to be to UL 1034.
7.2.1.5.8.1 (stair enclosure re-entry)		7.2.1.5.8.1 (stair enclosure re-entry)		7.2.1.5.7.1 (stair enclosure re-entry)		7.2.1.5.7.1 (stair enclosure re-entry)	
7.2.1.5.8.2 (where req's of 7.2.1.5.8 do not apply)		7.2.1.5.8.2 (where req's of 7.2.1.5.8 do not apply)		7.2.1.5.7.2 (where req's of 7.2.1.5.7 do not apply)		7.2.1.5.7.2 (where req's of 7.2.1.5.7 do not apply)	
7.2.1.5.8.3 (signage req'd when applying 7.2.1.5.8.2)		7.2.1.5.8.3 (signage req'd when applying 7.2.1.5.8.2)		7.2.1.5.7.3 (signage req'd when applying 7.2.1.5.7.2)		7.2.1.5.7.3 (signage req'd when applying 7.2.1.5.7.2)	
7.2.1.5.9 (stair enclosure roof access)		7.2.1.5.9 (stair enclosure roof access)		7.2.1.5.8 (stair enclosure roof access)	Revised to clarify intent if kept locked (to prevent access to roof).	7.2.1.5.8 (stair enclosure roof access)	Clarifies it's a door that allows access to the roof of a building (regardless if in a stair enclosure or not).
7.2.1.5.11 (req's for pairs of doors in MOE)		7.2.1.5.11 (req's for pairs of doors in MOE)	Editorial clarification.	7.2.1.5.9 (req's for pairs of doors in MOE)		7.2.1.5.9 (req's for pairs of doors in MOE)	
7.2.1.5.12* (no add'l devices on doors req'd to have panic or fire exit hardware)		7.2.1.5.12* (no add'l devices on doors req'd to have panic or fire exit hardware)		7.2.1.5.10* (no add'l devices on doors req'd to have not more than one releasing motion)	Revised to expand req's beyond doors req'd to panic or fire exit hardware.	7.2.1.5.10* (no add'l devices on doors req'd to have not more than one releasing motion)	
7.2.1.6* Special Locking Arrangements.		7.2.1.6* Special Locking Arrangements.		7.2.1.6* Special Locking Arrangements.		7.2.1.6* Special Locking Arrangements.	

NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>1</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>11</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
<b>7.2.1.6.1 Delayed-Egress Locking Systems.</b>		<b>7.2.1.6.1 Delayed-Egress Electrical Locking Systems.</b>	Editorial revision to title of section / name of locking system.	<b>7.2.1.6.1 Delayed-Egress Electrical Locking Systems.</b>		<b>7.2.1.6.1 Delayed-Egress Electrical Locking Systems.</b>	
<b>7.2.1.6.1.1</b> (req's for delayed egress locking systems)	Added recognition some delayed egress doors may be “pull” doors rather than “push” doors.	<b>7.2.1.6.1.1</b> (req's for delayed egress locking systems)	Editorial clarifications. Req'd sign req'd to comply with visual character req's of ANSI A117.1. Hardware for new installations to be listed to UL 294.	<b>7.2.1.6.1.1</b> (req's for delayed egress locking systems)		<b>7.2.1.6.1.1</b> (req's for delayed egress locking systems)	Added option for req'd listing to be to UL 1034.
<b>7.2.1.6.1.2</b> (req's for doors with access-controlled locks not applicable to delayed-egress doors)		<b>7.2.1.6.1.2</b> (req's for other electrical locking systems not applicable to delayed-egress doors)		<b>7.2.1.6.1.2</b> (req's for other electrical locking systems not applicable to delayed-egress doors)		<b>7.2.1.6.1.2</b> (req's for other electrical locking systems not applicable to delayed-egress doors)	
<b>7.2.1.6.2* Access-Controlled Egress Door Assemblies.</b> (req's for access-controlled egress doors)		<b>7.2.1.6.2* Sensor-Release of Electrical Locking Systems.</b> (req's for sensor-release electrical locking systems)	Editorial revision to title of section / name of locking system. Editorial clarifications. Hardware for new installations to be listed to UL 294	<b>7.2.1.6.2* Sensor-Release of Electrical Locking Systems.</b>		<b>7.2.1.6.2* Sensor-Release of Electrical Locking Systems.</b>	
				<b>7.2.1.6.2.1</b> (req's for sensor-release electrical locking systems)	Req's for these locking systems moved to this new subsection.	<b>7.2.1.6.2.1</b> (req's for sensor-release electrical locking systems)	Added option for req'd listing to be to UL 1034.
				<b>7.2.1.6.2.2</b> (req's for other electrical locking systems not applicable to sensor-release of electrical locking system doors)	New section to help prevent application conflicts.	<b>7.2.1.6.2.2</b> (req's for other electrical locking systems not applicable to sensor-release of electrical locking system doors)	
<b>7.2.1.5.6 Electrically Controlled Egress Door Assemblies.</b> (req's for electrically controlled egress door assemblies)		<b>7.2.1.5.6 Door Hardware Release of Electrically Locked Egress Door Assemblies.</b> (req's for door hardware release electrically locked	Revised title of section / name of this electrical locking system. Editorial refinements of the req's.	<b>7.2.1.6.3 Door Hardware Release of Electrically Locked Egress Door Assemblies.</b>		<b>7.2.1.6.3 Door Hardware Release of Electrically Locked Egress Door Assemblies.</b>	

NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>1</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>11</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
		egress door assemblies)					
				<b>7.2.1.6.3.1</b> (req's for door hardware release electrically locked egress door assemblies)	Req's for these locking systems moved to this new subsection. Operation of hardware revised to require direct and immediate interruption of power to the electric lock.	<b>7.2.1.6.3.1</b> (req's for door hardware release electrically locked egress door assemblies)	Added option for req'd listing to be to UL 1034.
				<b>7.2.1.6.3.2</b> (req's for other electrical locking systems not applicable to door hardware release electrically locked doors)	New section to help prevent application conflicts.	<b>7.2.1.6.3.2</b> (req's for other electrical locking systems not applicable to door hardware release electrically locked doors)	
<b>7.2.1.6.3 Elevator Lobby Exit Access Door Assemblies Locking.</b> (where permitted by chapters 11-43, req'ts for locking of elevator lobby exit access doors)		<b>7.2.1.6.3 Elevator Lobby Exit Access Door Assemblies Locking.</b> (where permitted by chapters 11-43, req'ts for locking of elevator lobby exit access doors)	Editorial clarifications.	<b>7.2.1.6.4 Elevator Lobby Exit Access Door Assemblies Locking.</b>		<b>7.2.1.6.4 Elevator Lobby Exit Access Door Assemblies Locking.</b>	
				<b>7.2.1.6.4.1</b> (where permitted by chapters 11-43, req'ts for locking of elevator lobby exit access doors)	Req's for these locking systems moved to this new subsection.	<b>7.2.1.6.4.1</b> (where permitted by chapters 11-43, req'ts for locking of elevator lobby exit access doors)	Added option for req'd listing to be to UL 1034.
				<b>7.2.1.6.4.2</b> (req's for other electrical locking systems not applicable to elevator lobby exit access doors)	New section to help prevent application conflicts.	<b>7.2.1.6.4.2</b> (req's for other electrical locking systems not applicable to elevator lobby exit access doors)	
<b>7.2.1.7 Panic Hardware and Fire Exit Hardware.</b>		<b>7.2.1.7 Panic Hardware and Fire Exit Hardware.</b>		<b>7.2.1.7 Panic Hardware and Fire Exit Hardware.</b>		<b>7.2.1.7 Panic Hardware and Fire Exit Hardware.</b>	

NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>1</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>11</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
7.2.1.7.1 (req'ts for panic and fire exit hardware)		7.2.1.7.1 (req'ts for panic and fire exit hardware)	Editorial clarifications.	7.2.1.7.1 (req'ts for panic and fire exit hardware)	Editorial clarifications.	7.2.1.7.1 (req'ts for panic and fire exit hardware)	
<b>7.2.1.13 Balanced Door Assemblies</b> (req's for panic hardware on balanced doors)		<b>7.2.1.13 Balanced Door Assemblies</b> (req's for panic hardware on balanced doors)		<b>7.2.1.7.2</b> (req's for panic hardware on balanced doors)	Revised to add pivoted-swinging door assembly to section.	<b>7.2.1.7.2</b> (req's for panic hardware on balanced doors)	
<b>7.2.1.7.2</b> (only approved fire-exit hardware; comply with UL 305 and BHMA A156.3)	Deleted sentence requiring only approved panic hardware to be used on non-fire-rated doors.	<b>7.2.1.7.2</b> (only approved fire-exit hardware; comply with UL 305 and BHMA A156.3)		<b>7.2.1.7.3</b> (only approved fire-exit hardware; comply with UL 305 and BHMA A156.3)		<b>7.2.1.7.3</b> (only approved fire-exit hardware; comply with UL 305 and BHMA A156.3)	
<b>7.2.1.7.3</b> (no device which prevents release of latch)		<b>7.2.1.7.3</b> (no device which prevents release of latch)		<b>7.2.1.7.4</b> (no device which prevents release of latch)		<b>7.2.1.7.4</b> (no device which prevents release of latch)	
<b>7.2.1.7.4</b> (no dogging of fire exit hardware unless listed)		<b>7.2.1.7.4</b> (no dogging of fire exit hardware unless listed)		<b>7.2.1.7.5</b> (no dogging of fire exit hardware unless listed)		<b>7.2.1.7.5</b> (no dogging of fire exit hardware unless listed)	
<b>7.2.1.8 Self-Closing Devices.</b>		<b>7.2.1.8 Self-Closing Devices.</b>		<b>7.2.1.8 Self-Closing Devices.</b>		<b>7.2.1.8 Self-Closing Devices.</b>	
<b>7.2.1.8.1*</b> (door req'd to be self-closing or automatic closing)		<b>7.2.1.8.1*</b> (door req'd to be self-closing or automatic closing)		<b>7.2.1.8.1*</b> (door req'd to be self-closing or automatic closing)		<b>7.2.1.8.1*</b> (door req'd to be self-closing or automatic closing)	
<b>7.2.1.8.2</b> (automatic-closing req's)		<b>7.2.1.8.2</b> (automatic-closing req's)		<b>7.2.1.8.2</b> (automatic-closing req's)		<b>7.2.1.8.2</b> (automatic-closing req's)	
<b>7.2.1.8.3</b> (elevator doors at recall floor)		<b>7.2.1.8.3</b> (elevator doors at recall floor)		<b>7.2.1.8.3</b> (elevator doors at recall floor)		<b>7.2.1.8.3</b> (elevator doors at recall floor)	

DISCLAIMER: BHMA provides this information as a service. Refer to the jurisdiction's building codes and the project requirements. If questions, consult the Authority Having Jurisdiction (AHJ).

NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>1</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>11</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
		<b>7.2.1.8.4 Delayed Action Closers.</b> (where delayed action closers permitted)	New section permitting delayed action closers on doors req'd to be self closing but not req'd to be automatic closing.	<b>7.2.1.8.4 Delayed Action Closers.</b> (where delayed action closers permitted)		<b>7.2.1.8.4 Delayed Action Closers.</b> (where delayed action closers permitted)	
<b>7.2.1.9* Powered Door Leaf Operation.</b>		<b>7.2.1.9* Powered Door Leaf Operation.</b>		<b>7.2.1.9* Powered Door Leaf Operation.</b>		<b>7.2.1.9* Powered Door Leaf Operation.</b>	
<b>7.2.1.9.1* General.</b> (in the event of power failure)		<b>7.2.1.9.1* General.</b> (in the event of power failure)		<b>7.2.1.9.1* General.</b> (in the event of power failure)	Editorial revisions.	<b>7.2.1.9.1* General.</b> (in the event of power failure)	
		<b>7.2.1.9.1.1</b> (A156.10)	New section referencing BHMA A156.10.	<b>7.2.1.9.1.1</b> (A156.10)		<b>7.2.1.9.1.1</b> (A156.10)	
		<b>7.2.1.9.1.2</b> (A156.19)	New section referencing BHMA A156.19.	<b>7.2.1.9.1.2</b> (A156.19)		<b>7.2.1.9.1.2</b> (A156.19)	
		<b>7.2.1.9.1.3</b> (A156.38)	New section referencing BHMA A156.38.	<b>7.2.1.9.1.3</b> (A156.38)		<b>7.2.1.9.1.3</b> (A156.38)	
<b>7.2.1.9.1.1</b> (max forces)		<b>7.2.1.9.1.4</b> (max forces)		<b>7.2.1.9.1.4</b> (max forces)		<b>7.2.1.9.1.4</b> (max forces)	
<b>7.2.1.9.1.2</b> (manual swing-out feature (breakout))		<b>7.2.1.9.1.5</b> (manual swing-out feature (breakout))		<b>7.2.1.9.1.5</b> (manual swing-out feature (breakout))	Editorial revisions.	<b>7.2.1.9.1.5</b> (manual swing-out feature (breakout))	
<b>7.2.1.9.1.3</b> (signage)		<b>7.2.1.9.1.6</b> (signage)		<b>7.2.1.9.1.6</b> (signage)		<b>7.2.1.9.1.6</b> (signage)	

DISCLAIMER: BHMA provides this information as a service. Refer to the jurisdiction's building codes and the project requirements. If questions, consult the Authority Having Jurisdiction (AHJ).

NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>1</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>11</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
7.2.1.9.1.4 (modified req's if occupant load < 50, signage)		7.2.1.9.1.7 (modified req's if occupant load < 50, signage)		7.2.1.9.1.7 (modified req's if occupant load < 50, signage)	Minor editorial revision.	7.2.1.9.1.7 (modified req's if occupant load < 50, signage)	
7.2.1.9.1.5* (min. clear width breakout mode for two-leaf opening)		7.2.1.9.1.8* (min. clear width breakout mode for two-leaf opening)		7.2.1.9.1.8* (min. clear width breakout mode for two-leaf opening)		7.2.1.9.1.8* (min. clear width breakout mode for two-leaf opening)	
7.2.1.9.1.6 (min. clear width breakout mode for two-leaf bi-parting door)		7.2.1.9.1.9 (min. clear width breakout mode for two-leaf bi-parting door)		7.2.1.9.1.9 (min. clear width breakout mode for two-leaf bi-parting door)		7.2.1.9.1.9 (min. clear width breakout mode for two-leaf bi-parting door)	
7.2.1.9.1.7 (door assemblies complying with 7.2.1.14 permitted)		7.2.1.9.1.10 (door assemblies complying with 7.2.1.14 permitted)		7.2.1.9.1.10 (door assemblies complying with 7.2.1.13 permitted)		7.2.1.9.1.10 (door assemblies complying with 7.2.1.13 permitted)	
7.2.1.9.1.8 (req's N.A. to detention and correction occupancies)		7.2.1.9.1.11 (req'ts N.A. to detention and correction occupancies)		7.2.1.9.1.11 (req'ts N.A. to detention and correction occupancies)		7.2.1.9.1.11 (req'ts N.A. to detention and correction occupancies)	
7.2.1.9.2 Self-Closing or Self-Latching Door Leaf Operation. (req's for power-operated doors which are also required to be self-closing or self-latching)		7.2.1.9.2 Self-Closing or Self-Latching Door Leaf Operation. (req's for power-operated doors which are also required to be self-closing or self-latching)		7.2.1.9.2 Self-Closing or Self-Latching Door Leaf Operation. (req's for power-operated doors which are also required to be self-closing or self-latching)	Editorial revisions.	7.2.1.9.2 Self-Closing or Self-Latching Door Leaf Operation. (req's for power-operated doors which are also required to be self-closing or self-latching)	
7.2.1.10 Revolving Door Assemblies.		7.2.1.10 Revolving Door Assemblies.		7.2.1.10 Revolving Door Assemblies.		7.2.1.10 Revolving Door Assemblies.	
7.2.1.10.1 (req's for revolving door assemblies)		7.2.1.10.1 (req's for revolving door assemblies)	New item (1) req's new revolving doors to comply with BHMA A156.27. Revised item (2) clarifies book-fold or breakout is per BHMA A156.27.	7.2.1.10.1 (req's for revolving door assemblies)		7.2.1.10.1 (req's for revolving door assemblies)	

DISCLAIMER: BHMA provides this information as a service. Refer to the jurisdiction's building codes and the project requirements. If questions, consult the Authority Having Jurisdiction (AHJ).

NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>1</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>11</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
			Limits Table 7.2.1.10.1 re: max speed to existing revolving doors.				
<b>7.2.1.10.2</b> (req's for revolving doors as component of MOE)		<b>7.2.1.10.2</b> (req's for revolving doors as component of MOE)		<b>7.2.1.10.2</b> (req's for revolving doors as component of MOE)		<b>7.2.1.10.2</b> (req's for revolving doors as component of MOE)	
<b>7.2.1.10.3</b> (max breakout force for revolving doors not in MOE)		<b>7.2.1.10.3</b> (max breakout force for revolving doors not in MOE)		<b>7.2.1.10.3</b> (max breakout force for revolving doors not in MOE)		<b>7.2.1.10.3</b> (max breakout force for revolving doors not in MOE)	
<b>7.2.1.10.4</b> (conditions where req's of 7.2.1.10.3 N.A.)		<b>7.2.1.10.4</b> (conditions where req's of 7.2.1.10.3 N.A.)		<b>7.2.1.10.4</b> (conditions where req's of 7.2.1.10.3 N.A.)		<b>7.2.1.10.4</b> (conditions where req's of 7.2.1.10.3 N.A.)	
<b>7.2.1.11 Turnstiles.</b> (req'ts for turnstiles)		<b>7.2.1.11 Turnstiles.</b> (req'ts for turnstiles)		<b>7.2.1.11 Turnstiles.</b> (req'ts for turnstiles)		<b>7.2.1.11 Turnstiles.</b> (req'ts for turnstiles)	
<b>7.2.1.12 Door Openings in Folding Partitions.</b> (req's for doors in folding partitions)		<b>7.2.1.12 Door Openings in Folding Partitions.</b> (req's for doors in folding partitions)		<b>7.2.1.12 Door Openings in Folding Partitions.</b> (req's for doors in folding partitions)		<b>7.2.1.12 Door Openings in Folding Partitions.</b> (req's for doors in folding partitions)	Editorial revisions in 7.2.1.12.2.
<b>7.2.1.14 Special-Purpose Horizontally Sliding Accordion or Folding Door Assemblies.</b> (req's for special purpose horizontally sliding accordion or folding door assemblies)	Revised title of section to Special-Purpose Horizontally Sliding Accordion or Folding Door Assemblies. No technical changes.	<b>7.2.1.14 Special-Purpose Horizontally Sliding Accordion or Folding Door Assemblies.</b> (req's for special purpose horizontally sliding accordion or folding door assemblies)		<b>7.2.1.13 Special-Purpose Horizontally Sliding Accordion or Folding Door Assemblies.</b> (req's for special purpose horizontally sliding accordion or folding door assemblies)	Editorial revisions.	<b>7.2.1.13 Special-Purpose Horizontally Sliding Accordion or Folding Door Assemblies.</b> (req's for special purpose horizontally sliding accordion or folding door assemblies)	

NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>1</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>11</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
<b>7.2.1.15 Inspection of Door Openings.</b>		<b>7.2.1.15 Inspection of Door Openings.</b>		<b>7.2.1.14 Inspection of Door Openings.</b>		<b>7.2.1.14 Inspection of Door Openings.</b>	
<b>7.2.1.15.1*</b> (req's annual inspections where req'd per chapters 11-43)	Req't to inspect fire-rated door assemblies per NFPA 80 moved to 8.3.3.13 (from 7.2.1.15.2). Req't to inspect smoke doors per NFPA 105 included in req's to maintain smoke doors per NFPA 105 in 8.2.2.4(3).	<b>7.2.1.15.1*</b> (req's annual inspections where req'd per chapters 11-43)	Added door hardware-release electrically locked doors to list.	<b>7.2.1.15.1*</b> (req's annual inspections where req'd per chapters 11-43)		<b>7.2.1.15.1*</b> (req's annual inspections where req'd per chapters 11-43)	
<b>7.2.1.15.2</b> (conditions for extending inspection interval)		<b>7.2.1.15.2</b> (conditions for extending inspection interval)		<b>7.2.1.14.2</b> (conditions for extending inspection interval)		<b>7.2.1.14.2</b> (conditions for extending inspection interval)	
<b>7.2.1.15.2.1</b> (performance-based inspection program assurance)		<b>7.2.1.15.2.1</b> (performance-based inspection program assurance)		<b>7.2.1.14.2.1</b> (performance-based inspection program assurance)		<b>7.2.1.14.2.1</b> (performance-based inspection program assurance)	
<b>7.2.1.15.2.2</b> (technical justification for performance-based inspection)		<b>7.2.1.15.2.2</b> (technical justification for performance-based inspection)		<b>7.2.1.14.2.2</b> (technical justification for performance-based inspection)		<b>7.2.1.14.2.2</b> (technical justification for performance-based inspection)	
<b>7.2.1.15.3</b> (written record of inspectoins)		<b>7.2.1.15.3</b> (written record of inspectoins)		<b>7.2.1.14.3</b> (written record of inspectoins)		<b>7.2.1.14.3</b> (written record of inspectoins)	
<b>7.2.1.15.4</b> (functional testing)		<b>7.2.1.15.4</b> (functional testing)		<b>7.2.1.14.4</b> (functional testing)		<b>7.2.1.14.4</b> (functional testing)	
<b>7.2.1.15.5</b> (visual inspections)		<b>7.2.1.15.5</b> (visual inspections)		<b>7.2.1.14.5</b> (visual inspections)		<b>7.2.1.14.5</b> (visual inspections)	



NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>1</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>11</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
7.2.1.15.6 (min. items to verify)	Added two req's to the list regarding req'd hardware marking, and emergency lighting.	7.2.1.15.6 (min. items to verify)		7.2.1.14.6 (min. items to verify)		7.2.1.14.6 (min. items to verify)	
<b>Chapter 18 New Health Care Facilities</b>							
<b>18.2 Means of Egress Requirements.</b>							
<b>18.2.1 General.</b>							
<b>18.2.2* Means of Egress Components.</b>							
<b>18.2.2.1 Components Permitted.</b>							
<b>18.2.2.2 Doors.</b>							
<b>18.2.2.2.1</b>							

DISCLAIMER: BHMA provides this information as a service. Refer to the jurisdiction's building codes and the project requirements. If questions, consult the Authority Having Jurisdiction (AHJ).

NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>1</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>11</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
18.2.2.2.2							
18.2.2.2.3							
18.2.2.2.4							
18.2.2.2.5							
18.2.2.2.5.1*							
18.2.2.2.5.2*							
18.2.2.2.6							
18.2.2.2.7*							
18.2.2.2.8							

DISCLAIMER: BHMA provides this information as a service. Refer to the jurisdiction's building codes and the project requirements. If questions, consult the Authority Having Jurisdiction (AHJ).

NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>1</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>11</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
18.2.2.2.9							
18.2.2.2.10							
18.2.2.2.10.1							
18.2.2.2.10.2							
18.2.2.3 Stairs.							
Chapter 19 Existing Health Care Facilities							
19.2 Means of Egress Requirements.							
19.2.1 General.							

DISCLAIMER: BHMA provides this information as a service. Refer to the jurisdiction's building codes and the project requirements. If questions, consult the Authority Having Jurisdiction (AHJ).

NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>1</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>11</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
19.2.2* Means of Egress Components.							
19.2.2.1 Components Permitted.							
19.2.2.2 Doors.							
19.2.2.2.1							
19.2.2.2.2							
19.2.2.2.3							
19.2.2.2.4							
19.2.2.2.5							
19.2.2.2.5.1*							

DISCLAIMER: BHMA provides this information as a service. Refer to the jurisdiction's building codes and the project requirements. If questions, consult the Authority Having Jurisdiction (AHJ).

NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>1</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>11</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
19.2.2.2.5.2*							
19.2.2.2.6							
19.2.2.2.7*							
19.2.2.2.8							
19.2.2.2.9							
19.2.2.2.10							
19.2.2.2.10.1							
19.2.2.2.10.2							
19.2.2.3 Stairs.							

DISCLAIMER: BHMA provides this information as a service. Refer to the jurisdiction's building codes and the project requirements. If questions, consult the Authority Having Jurisdiction (AHJ).

NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>1</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>11</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
<b>Chapter 20 New Ambulatory Health Care Occupancies</b>							
<b>20.2 Means of Egress Requirements.</b>							
<b>20.2.1 General.</b>							
<b>20.2.2 Means of Egress Components.</b>							
<b>20.2.2.1</b>							
<b>20.2.2.2</b>							
<b>20.2.2.3</b>							
<b>20.2.2.4</b>							

DISCLAIMER: BHMA provides this information as a service. Refer to the jurisdiction's building codes and the project requirements. If questions, consult the Authority Having Jurisdiction (AHJ).

NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>1</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>11</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
20.2.2.5							
20.2.11.2 Lockups.							
Chapter 21 Existing Ambulatory Health Care Occupancies							
21.2 Means of Egress Requirements.							
21.2.1 General.							
21.2.2 Means of Egress Components.							
21.2.2.1							
21.2.2.2							

DISCLAIMER: BHMA provides this information as a service. Refer to the jurisdiction's building codes and the project requirements. If questions, consult the Authority Having Jurisdiction (AHJ).

NFPA 101-2015		NFPA 101-2018		NFPA 101-2021		NFPA 101-2024 – approved revisions <sup>1</sup>	
Section and Title	Summary of Changes 2012 to 2015 NFPA 101	Section and Title	Summary of Changes 2015 to 2018 NFPA 101	Section and Title <sup>11</sup>	Summary of Changes 2018 to 2021 NFPA 101	Section and Title	Summary of Changes 2021 to 2024 NFPA 101
21.2.2.3							
21.2.2.4							
21.2.2.5							
21.2.2.6*							
21.2.11.2 Lockups.							

<sup>i 1</sup> Revisions to NFPA 101-2024 IBC reflect actions taken during NFPA's code development process.

<sup>ii 11</sup> Section numbering highlighted in yellow indicates renumbered and / or rearranged sections.